

Pump & Well Info

Customer Name: 62107 off

Field Name: #1 middle well

Date: 5/29/23

Well Diameter: 12 inches

Static: 14 feet

Well Depth: 40 feet

Type of casing: PVC Steel

Well ID#: _____

Pump Type: Submersible Turbine

Motor HP: 7 1/2 HP

Length of column: 31 feet 3" drop shot

Tail pipe: Yes No Length: _____ feet

Pump Brand: _____

Pump Stages: _____

Power Type: Electric Diesel

VFD: Yes No

Pump Panel: Yes No

Rotophase: Yes No

Take a picture of pump setup

5X12 seal

oil chem

need new seal tight

Pump & Well Info

Customer Name: OALON OFF

Field Name: #1 South well

Date: 5/28/23

Well Diameter: 12 inches

Static: 11 feet

Well Depth: 46 feet

Type of casing: PVC Steel

Well ID#: _____

Pump Type: Submersible Turbine

Motor HP: 20 HP

Length of column: 31 feet 5" drop

Tail pipe: Yes No Length: _____ feet

Pump Brand: _____

Pump Stages: _____

Power Type: Electric Diesel

VFD: Yes No

Pump Panel: Yes No

Rotophase: Yes No

noel new drop

8" chem valve

Take a picture of pump setup

Pump & Well Info

Customer Name:

Galen Off

Field Name:

#1 Pivot Road well

Date:

5/29/23

Well Diameter:

10 inches

Static:

13 feet

Well Depth:

46 feet

Type of casing:

PVC Steel

Well ID#:

Pump Type:

Submersible Turbine

Motor HP:

25 HP sub 5" drop shot

Length of column:

39 feet

Tail pipe:

Yes No Length: _____ feet

Pump Brand:

Pump Stages:

Power Type:

Electric Diesel

VFD:

Yes No

Pump Panel:

Yes No

Rotophase:

Yes No

Take a picture of pump setup

need new seal tight pipe

#

GA 53 16

Pump & Well Info

Customer Name: Alon opp

Field Name: #2 middle well

Date: 5/28/23

Well Diameter: 10 inches

Static: 14 feet

Well Depth: 44 feet

Type of casing: PVC Steel

Well ID#: _____

Pump Type: Submersible Turbine

Motor HP: 15 HP

Length of column: 37 feet 4" drop

Tail pipe: Yes No Length: _____ feet

Pump Brand: _____

Pump Stages: _____

Power Type: Electric Diesel

VFD: Yes No

Pump Panel: Yes No

Rotophase: Yes No

*Need new pipe
1" seal tight*

Take a picture of pump setup

Pump & Well Info

Customer Name:

6 Alon opps

Field Name:

#2 East well

Date:

5/28/23

Well Diameter:

10 inches

Static:

13 feet

Well Depth:

48 feet

Type of casing:

PVC

Steel

Well ID#:

Pump Type:

Submersible

Turbine

Motor HP:

20 HP

Length of column:

40 feet CL 4"

Tail pipe:

Yes

No

Length: _____ feet

Pump Brand:

Pump Stages:

Power Type:

Electric

Diesel

VFD:

Yes

No

Pump Panel:

Yes

No

Rotophase:

Yes

No

Take a picture of pump setup

Pump & Well Info

Customer Name:

Gullen off

Field Name:

#2 pivot well

Date:

3/28/

Well Diameter:

10 inches

Static:

15 feet

Well Depth:

45 feet

Type of casing:

PVC Steel

Well ID#:

Pump Type:

Submersible Turbine

Motor HP:

10 HP sub

Length of column:

37 feet 4" Drop

Tail pipe:

Yes No Length: _____ feet

Pump Brand:

Pump Stages:

Power Type:

Electric Diesel

VFD:

Yes No

Pump Panel:

Yes No

Rotopulse:

Yes No

Take a picture of pump setup

Need
some pipe
1" Seal tight

Pump & Well Info

Customer Name:

Galena OPP

Field Name:

#3 pivot well

Date:

5/28/23

Well Diameter:

12 inches

Static:

9 feet

Well Depth:

50 feet

Type of casing:

PVC Steel

Well ID#:

Pump Type:

Submersible

Turbine

Motor HP:

40 HP

Length of column:

40 feet

Tail pipe:

Yes No

Length: 5 feet

Pump Brand:

MLR

Pump Stages:

4-stage loc

Power Type:

Electric Diesel

VFD:

Yes No

Pump Panel:

Yes No

Rotophase:

Yes No

*need
couple new
pipe
need head stuff*

Take a picture of pump setup

Pump & Well Info

Customer Name:

Galan opp

Field Name:

#4 North Turbine

Date:

5/28/23

Well Diameter:

12 inches

Static:

14 feet

Well Depth:

30 feet

Type of casing:

PVC Steel

Well ID#:

Pump Type:

Submersible

Turbine

Motor HP:

40 HP

Length of column:

30 feet 10' tail pipe

Tail pipe:

Yes

No

Length: 10 feet

Pump Brand:

WLR

Pump Stages:

4 stage 100

Power Type:

Electric

Diesel

VFD:

Yes

No

Pump Panel:

Yes

No

Rotophase:

Yes

No

Take a picture of pump setup

need couple new pipe

Need new 1"

seal tight

Need new head shaft

Pump & Well Info

Customer Name: Galen opps

Field Name: #4 South well

Date: 5/29/13

Well Diameter: 12 inches

Static: 14 feet

Well Depth: 54 feet

Type of casing: PVC Steel

Well ID#: _____

Pump Type: Submersible Turbine
3" Discharge pump

Motor HP: 15 HP

Length of column: 38 feet *6" shot new pipe*

Tail pipe: Yes No Length: _____ feet

Pump Brand: _____

Pump Stages: _____

Power Type: Electric Diesel

VFD: Yes No

Pump Panel: Yes No

Rotophase: Yes No

1" seal tight

Take a picture of pump setup